

1 N. University Drive, Suite 3500B Plantation, Florida 33324

Phone: 954-765-4500 Email: <u>rulesboard@broward.org</u> www.broward.org/CodeAppeals

2024 Voting Members

Chair Gregg D'Attile, Mechanical Contractor

Vice-Chair Ron Burr, Swimming Pool Contractor

Mr. Stephen Bailey, P.E., Electrical Engineer

Mr. John Famularo, Roofing Contractor

Mrs. Shalanda Giles Nelson, General Contractor

Mr. Robert A. Kamm, P.E., Mechanical Engineer

Mr. Daniel Lavrich, P.E., S.I., F.ASCE, F.SEI, Structural Engineer

Mr. Sergio Pellecer, Fire Service Professional

Mr. Daniel Rourke,

Master Plumber Mr. John Sims.

Master Electrician

Mr. Dennis A. Ulmer. Consumer Advocate

Ms. Lynn E. Wolfson, Disabled Community Representative

Mr. Abbas H. Zackria, CSI, Architect

2024 Alternate Board Members

Mr. Steven Feller, P.E., Mechanical Engineer

Mr. Jeff Falkanger, Architect

Mr. Alberto Fernandez,

General Contractor Mr. David Rice, P.E.,

Electrical Engineer

Mr Robert Taylor. Fire Service Professional

Mr. James Terry, Master Plumber

Mr. David Tringo, Master Electrician

Mr. Derek A. Wassink, P.E,R.A.,S.I., S.T.S.2., Structural Engineer

VACANT,

Roofing Contractor

Board Attorney Charles M. Kramer, Esq.

Board Administrative Director Dr. Ana Barbosa

— Established 1971 —

BROWARD COUNTY BOARD OF RULES AND APPEALS

FBC 8TH EDITION (2023) **FORMAL INTERPRETATION (#25)**

DATE: October 12, 2023 TO:

FROM:

Dr. Ana Barbosa, Administrative Director

PVC pines and ferror SUBJECT: PVC pipes and fittings within plenums in the residential portion

of R-2 and R-3 occupancies.

At its regularly scheduled meeting on October 12, 2023, the Broward County Board of Rules and Appeals approved an interpretation of the following sections of Chapter 1, Broward County Amendments to the 8th Edition (2023) Florida Mechanical Code (FMC):

- FMC 602.2.1, Materials within plenums, Exception 5.3
- FMC 602.2.1.5 Discrete plumbing and mechanical products in plenums.
- FMC 602.2.1.7 Plastic plumbing pipe and tube.

Formal Interpretation:

The use of PVC pipes and fittings for the removal of condensate in air handler closets used as plenums in the residential portion of R-2 and R-3 occupancies is acceptable when complying with all the following conditions:

- 1. Acceptance is limited to schedule 40 PVC pipe and fittings of 3/4" or 1" nominal diameter.
- 2. Acceptance is limited to a total pipe length of 48" or less.
- 3. PVC pipes and fittings shall comply with ASTM standards referred to in FMC 1202.4 and 1202.5.

EFFECTIVE DATE: December 31, 2020 EFFECTIVE DATE: December 31, 2023

*** PLEASE POST AT YOUR PERMIT COUNTER ***

Page 1 of 1 F.I. #25